

Baseline Data

Rwanda

District of Kicukiro

Sectors of Gahanga, Kanombe, Kigrama and Masaka

126 water points

597 households

31 public institutions

Water Point Data

Household Data

Public Institution Data



Improved System

87% of water systems assessed were improved systems

91% of households collected water from an improved system

93% of the public institutions had improved water systems

1 school had a water point that was part of a Water For People project

Usage

63  each improved system was being used by an average of 63 people

of the 8.9% that did not collect water from an improved system, 35% reported that there was an improved system available but they did not use it **35%**

545 students, staff, patients, teachers using each improved water point

Quality

0 **88%** water quality testing was conducted at 18 of the improved water points and 88% had 0 fecal coliform present

70% reported that they treat their drinking water at home predominately by boiling or with chlorine

3/0 water quality testing was conducted in 3 schools and all of them had 0 fecal coliforms

Quantity

provided enough water for the community every day of the year **41%**

64% reported that the improved systems did not provide enough water every day of the year

did not provide enough water every day **41%**

Distance

100 meters the most commonly reported distance households reported walking to collect water

Financial

75% reported that a tariff or user fee was collected

reported that financial records were kept **11%**

87% reported that they pay a tariff for water

Functionality

50% of the water points had been down for more than 1 day in the last month

55% of the communities reported that they had no spare parts on hand for the water system

reported that the improved water system was down for more than 1 day in the past month **14%**

Sanitation

63% improved sanitation facilities

22% had water nearby for hand washing
18% had soap available **22%/18%**

87% had improved sanitation facilities **33%** had problems

had water available for handwashing near latrines **63%** **37%** had soap available

3 schools had sanitation projects supported by Water For People project